



# Annual Drinking Water Quality Report

**FAIRBURY**

**IL1050350**

Annual Water Quality Report for the period of January 1 to December 31, 2013

<p>Annual Water Quality Report for the period of January 1 to December 31, 2013</p> <p>This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.</p> <p>The source of drinking water used by FAIRBURY is Ground Water.</p> <p>For more information regarding this report contact:</p> <p>Mr. Leroy E. McPherson</p> <p>815.692.2743</p> <p>Este informe contiene informacion muy importante sobre el agua que usted bebe. Traduzcalo o hable con alguien que lo entienda bien.</p>	<p><b>Source of Drinking Water</b></p> <hr/> <p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p> <hr/> <p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"><li>-Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.</li><li>-Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.</li><li>-Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.</li><li>-Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.</li><li>-Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.</li></ul>	<p>Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426.4791.</p> <hr/> <p>In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.</p> <p>Some people may be more vulnerable to contaminants in drinking water than the general population.</p> <hr/> <p>Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426.4791.</p> <p>If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safewater/lead">http://www.epa.gov/safewater/lead</a>.</p>
---	--	---

**Source Water Information**

Source Water Name	Type of Water	Report Status	Location
WELL 1 (40040)	GW	_____	SOUTH OF PLANT ON E SIDE OF FIRST
WELL 3 (40042)	GW	_____	NE OF PLANT
WELL 4 (40043)	GW	_____	NE OF PLANT 300 FT E OF WELL 3
WELL 5 (40044)	GW	_____	E OF PLANT, S OF LAGOON
WELL 6 (00829)	GW	_____	SE CORNER OF FAIRGROUNDS TRACK
WELL 7 (00830)	GW	_____	FIRST WELL S ON FIRST ST

## **Source Water Assessment**

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop in City Hall or call our water operator at 815.692.2033. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

To determine Fairbury's susceptibility to groundwater contamination, a Well Site Survey, published in 1991 by the Illinois EPA, was reviewed. Based on the information obtained in this document, two potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Fairbury community water supply wells. These include Westview Elementary School, and the City of Fairbury. The community's source water is susceptible to VOC and SOC contamination although no detection of any quantifiable levels were detected in the finished water. The basis for this determination is the location of the potential sources within the recharge areas of the city's wells. However, as a result of monitoring conducted at the wells and entry point to the distribution system, the land-use activities and source water protection initiatives by the city (refer to the following section of this report), the Fairbury Community Water Supply's source water has a low susceptibility to IOC contamination. Furthermore, in anticipation of the U.S. EPA's proposed Groundwater Rule, the Illinois EPA has determined that Fairbury's community water supply wells have a low susceptibility to viral contamination. This determination is based upon the completed evaluation of the following criteria used in the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; analysis of monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. However, having stated this, the "[U.S.] EPA is proposing to require States to identify systems in karst, gravel and fractured rock aquifer systems as sensitive and these systems must perform routine source water monitoring". Because the community's wells are open to an unconfined sand and gravel aquifer, the Illinois EPA evaluated the well hydraulics associated with Fairbury's well field. From 29 to 48 feet of overburden overlie the intervals of the wells. This should provide an adequate degree of filtration to prevent the movement of pathogens into the wells.

## 2013 Regulated Contaminants Detected

### Lead and Copper

Definitions:

**Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	06/17/2011	1.3	1.3	0.034	0	ppm	N	Erosion of natural deposits; Leaching from wood preservative; Corrosion of house hold plumbing systems.

### Water Quality Test Results

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum residual disinfectant level goal or MRDLG:** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Maximum residual disinfectant level or MRDL:** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Definitions:** The following tables contain scientific terms and measures, some of which may require explanation.

**ppb:** micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

**na:** not applicable.

**Avg:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**ppm:** milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

## Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	12/31/2013	1.2	1 - 1.5	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)*	2013	10.1	10.1 - 10.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2013	25.87	25.87 - 25.87	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	10/10/2012	0.0084	0.0084 - 0.0084	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	10/10/2012	1.08	1.08 - 1.08	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promote strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2013	1	0.88 – 0.88	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Sodium	10/10/2012	21	21 - 21			ppm	N	Erosion from naturally occurring deposits; Used in water softener regeneration.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Gross alpha excluding radon and uranium	7/10/2012	0.583	0.583 – 0.583	0	15	pCi/L	N	Erosion of natural deposits.